

e 28

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHTPLACE
NEW DELHI- 110001

No.F6/DFS/MS/School/SZ/2024p/ 106

Dated: 15/02/2024

FIRE SAFETY CERTIFICATE

Certified that the **Banasthali Public School** at G-Block, Plot No.-16, Vikaspuri, New Delhi-18, comprised of ground plus two upper floors owned/occupied by Banasthali Public School was granted FSC vide letter no. No. F.6/DFS/MS/School/SZ/2021/28 dated 11.01.2021. The school building was re-inspected by the officer concerned of this department on 09.02.2024 in the presence of Smt. Anubha Goyal (Principal) and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules,2010 and found that the building is fit for occupancy class B '**Educational Building**' with effect from ..15/02/2024. for a period of three years in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on.....15/02/2024.....at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service
9/4. 4

Copy to:-

The Principal, Banasthali Public School, G-Block, Plot No.-16, Vikaspuri, New Delhi-18.
The Director of Education, GNCT of Delhi, Old secretariat, New Delhi- 110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.